



## THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3883

---

### ADDENDUM NO. 2

## Wickers Field Athletic Trailers – ITB 18-038

This addendum is issued as supplemental information to the bid package for clarification of certain matters of both a general and a technical nature. The referenced Invitation to Bid (ITB) package is hereby amended in accordance with the following items:

### **Requests for Information and Clarifications:**

- 1) *What was the name of the manufacturer of the modular utilized for the basis of design?*
  - a. **Vesta Modular – See bid alternate No. 3 and part 6 of the Contract Documents.**
- 2) *Confirm the main distribution panel will be 120/240V; Single Phase feed over-head.*
  - a. **Contractor to confirm that with the manufacturer.**
- 3) *Please provide the ampacity of service entrance.*
  - a. **Standard single phase 125 amp panel.**

All Bidders shall acknowledge receipt and acceptance of this Addendum by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

---

Signature

---

Name of Business

**PRE PROPOSAL INQUIRY FORM**

Wickers Field Athletic Trailer - ITB 18-038

OFFEROR NAME: <b>Sea Tech of the Florida Keys</b>		DATE: 11SEP2018	
ADDRESS: <b>131 Palomino Horse Trail, Big Pine Key, FL 33043</b>			
PHONE NUMBER: <b>(305) 872-0888 office (305)304-8406 cell</b>			
EMAIL: <b>RYONL@SEATECH.CC</b>			
Question No.	Reference (Sect/Para/Page)	QUESTION	GOVERNMENT RESPONSE
1	Part 6	What was the name of the manufacturer of the modulators utilized for the basis of design?	
2		Confirm the Main Distribution Panel will be 120/240V; Single Phase feed over-head	
3		Please, provide ampacity of Service Entrance	