



THE CITY OF KEY WEST

1300 White St. Key West FL 33040 Phone: (305) 809-3700

Invitation to Bid # 19-007
WWTP WELL REPAIR AND MECHANICAL INTEGRITY TESTING
Project No. SE35041701

ADDENDUM # 1

December 11, 2018

This addendum includes answers to questions regarding drawing details and bridge limits:

Q: Can you please verify the information provided in the bid with regards to weight limits for Fleming Bridge?

A: **Photo attached below of the weight limits.**

Q: Regarding the concrete work on the repair of IW-1, in the concrete notes number 9 states that all accessories are to be “galvanized”. Please clarify if this is to include bars and fabric mentioned in notes 5 & 6 such as the #5 Vert. and #4 Ties @ 12” described in the drawing Detail B.

A: **Note 9 pertains only to accessories such as spacers, chairs, etc. It does not pertain to the #5 vert and #4 ties.**

Q: If more readily available, could a 36” Tube be used to form the encasement around the casing?

A: **Yes.**

Q: Could the MIT be performed on IW-2 prior to the repair work being started on IW-1?

A: **Yes.**

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 by acknowledging addendum in their proposal or by submitting the addendum with the bid package. Bids submitted without acknowledgement or without this addendum may be considered non-responsive.

Signature

Name of Business or Corporation



THE CITY OF KEY WEST
1300 White St. Key West FL 33040 Phone: (305) 809-3700

