



THE CITY OF KEY WEST

Post Office Box 1409
Key West, FL 33041-1409

**ADDENDUM NO. 1
ITB 15-023
PROJECT Painting of Key West Fire
Department Exterior and Police
Interior/Exterior**

This addendum is issued as supplemental information to the bid package for clarification of certain matters of both a general and a technical nature. The referenced bid package is hereby addended in accordance with the following items:

1. Painting of the new roof flashings on the rotunda need to be painted

We are not painting the flashings on the rotunda

2. A simple layout of the interior of the police department for dimension's

Due to security constraints prints will be provided by Marcus A. Davila or Richard Sarver at 633 Palm Ave Key West FL, 33040 for measurement and review

3. What type of paint to be used on the floor of the stairwell in the police department

You will need to use Sherwin Williams all surface oil based Paint A11T214 on the stairwell floor or equivalent.

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature

Name of Business