



NOTES:

1. SANITARY SEWER MAIN OR LATERAL SHALL BE A CONTINUOUS LENGTH OF DUCTILE IRON PIPE TO EXTEND 2' MIN., WITHIN SIDE OF THE DRAINAGE DITCH WITH NO FITTINGS OR JOINTS WITHIN THE DITCH. PVC PIPE MAY BE USED IF AN APPROPRIATE LENGTH OF D.I.P.* IS USED AS A CASING FOR THE PVC SEWER PIPE IN LIEU OF THE ABOVE. SEAL ENDS WITH GROUT.

2. APPROVED GASKET

3. DOUBLE HUB (D.I.P. TO VC) - ADJUST STAINLESS STEEL REPAIR COUPLING OR PVC DOUBLE BELL TRANSITION COUPLING.

4. EXISTING SEWER PIPE (VITRIFIED CLAY OR PVC)

* D.I.P. SHALL BE ONE SIZE RANGE LARGER THAN THE PVC PIPE UNLESS OTHERWISE APPROVED

6. SOIL CONDITIONS MAY REQUIRE HEADWALL



City of Key West

Engineering Services
3132 Flagler Avenue, Key West, FL 33040

TITLE
SLEEVE FOR STORM SEWER CONFLICTS

DRAWN
JTJ
SCALE
NTS

DETAIL

JUL 2015
DETAIL
17