



REPAIRS FOR ASPHALT TRENCH

1. REMOVE UNSUITABLE BACKFILL MATERIAL ABOVE THE TOP OF PIPE. REPLACE WITH #57 STONE, FLOWABLE FILL OR OTHER SELECT BACKFILL MATERIAL APPROVED BY THE CITY. IF FLOWABLE FILL IS USED IT SHALL HAVE A MINIMUM RATING OF 500 PSI.
2. BACKFILL MATERIAL SHALL BE COMPACTED TO 95% STANDARD PROCTOR AND SHALL GENERALLY BE COMPACTED IN 6" LIFTS WITH A VIBRATORY COMPACTOR.
3. THE REPLACEMENT BASE SHALL CONSIST OF COMPACTED LIMEROCK AND SHALL HAVE A MINIMUM DEPTH OF 12".
4. ADJUST ALL EXISTING METER BOXES AND MANHOLE RINGS IMPACTED BY CONSTRUCTION.
5. THE REPLACEMENT ASPHALT SHALL MATCH THE EXISTING STRUCTURAL AND FRICTION COURSES FOR TYPE AND THICKNESS.



City of Key West

Engineering Services
3132 Flagler Avenue, Key West, FL 33040

TITLE

REPAIRS FOR ASPHALT TRENCH

DRAWN
JTJ
SCALE
NTS

SECTION

JUL 2015
DETAIL
21