



NOTES:

- | | |
|---|--|
| <p>1. CONTRACTOR SHALL PROVIDE AN ADEQUATE SUPPLY OF 22.5° AND 45° BENDS TO MEET VARYING FIELD CONDITIONS</p> <p>2. PROVIDE APPROVED PLUG OR JOINT FOR DISSIMILAR GRAVITY SEWER PIPE FOR SERVICE CONNECTION</p> <p>3. LENGTH OF SERVICE PIPE VARIES AT EACH SERVICE CONNECTION AND SHALL BE PROVIDED AS REQUIRED. TERMINATE SERVICE AT LOCATION DIRECTED BY ENGINEER</p> <p>4. INSTALL MULTIPLE METER BOXES AS REQUIRED TO BRING TO GRADE</p> | <p>5. IF SERVICE PIPE MATERIAL IS NOT THE SAME AS SEWER MAIN, CONNECTION SHALL BE APPROVED PRIOR TO CONSTRUCTION</p> <p>6. SEE SPECIFICATIONS FOR SERVICE CONNECTION MARKERS</p> <p>7. SAW CUT EXISTING CONCRETE SIDE WALK FOR INSTALLATION OF SERVICE PIPE AND METER BOX. PLACE GROUT AROUND METER BOX. RESTORE SIDEWALK TO ORIGINAL CONDITION.</p> <p>8. CONNECT AT TRENCH WALL OR AT ROW LINE, AS DIRECTED BY ENGINEER</p> <p>9. PROVIDE WHEN CONNECTING AT TRENCH WALL</p> |
|---|--|



City of Key West

Engineering Services
3132 Flagler Avenue, Key West, FL 33040

TITLE

TYPICAL SERVICE CONNECTION

DRAWN

JTJ

SCALE

NTS

DETAIL

JUL 2015

DETAIL

12