



## ASPHALT UTILITY TRENCH

1. BACKFILL MATERIAL SHALL CONSIST OF #57 STONE, FLOWABLE FILL, OR OTHER SELECT BACKFILL MATERIAL APPROVED BY THE CITY. IF FLOWABLE FILL IS USED IT SHALL HAVE A MINIMUM RATING OF 500 PSI.
2. BACKFILL MATERIAL SHALL BE COMPACTED TO 95% STANDARD PROCTOR AND SHALL GENERALLY BE COMPACTED IN 6" LIFTS WITH A VIBRATORY COMPACTOR.
3. THE REPLACEMENT BASE SHALL CONSIST OF COMPACTED LIMEROCK AND SHALL HAVE A MINIMUM DEPTH OF 12".
4. ADJUST ALL EXISTING METER BOXES AND MANHOLE RINGS IMPACTED BY CONSTRUCTION.
5. THE REPLACEMENT ASPHALT SHALL MATCH THE EXISTING STRUCTURAL AND FRICTION COURSES FOR TYPE AND THICKNESS.



City of Key West

Engineering Services  
3132 Flagler Avenue, Key West, FL 33040

TITLE

ASPHALT UTILITY TRENCH

DRAWN  
JTJ  
SCALE  
NTS

SECTION

JUL 2015  
DETAIL  
20